

**THE COMMISSIONERS OF FIRE DISTRICT NO. 1
IN THE TOWNSHIP OF MANTUA, COUNTY OF GLOUCESTER**

Resolution #2017-05

**Authorizing Award of Contract Relative to Installation of a Generator at the
Jackson Road Station**

WHEREAS, the Commissioners have advertised for bids concerning the Installation of a Generator at the Jackson Road Station; and

WHEREAS, bids have been received and reviewed concerning this project; and

WHEREAS, the Commissioners deem it to be in the best interest of the fire district to award a contract relative to said bid in the amount of \$17,490.00.

NOW THEREFORE, be it RESOLVED by the Commissioners of Fire District No. 1 in the Township of Mantua, County of Gloucester as follows:


- (1) An award of contract is hereby made to M & M Electric, LLC pursuant to the bid proposal.
- (2) This award of contract is contingent upon the providing of the appropriate performance bond.

RECORD OF VOTE

Members	VACARINO	HOWARTH	HAUSS	JONES	CAMPBELL
Yes		✓	✓	✓	✓
No					
Not Voting					
Absent					

Certification

I, Chuck Jones, Secretary of the Commissioners of Fire District No. 1 in the Township of Mantua, County of Gloucester, hereby certify that the foregoing resolution was duly adopted by the Commissioners at a meeting held on February 2, 2017.



Chuck Jones, Secretary

279 Richwood Road
 Mullica Hill, NJ 08062
 License # 12147
 856-582-7440 Telephone


PROPOSAL

Date	Proposal #
12/29/2016	2760

Name / Address
Mantua Township Fire District Attn: Nick Vacarino 191 Jackson Road Mantua, NJ 08051

Description	Total
<p>M&M Electrical LLC proposes to provide labor, material and equipment to perform the following Electrical work on the 48KW Generator Installation at the Mantua Twp Fire District facility located on Union Road at 191 Jackson Road, Mantua, NJ. Proposal based on walk thru with a Representative of Mantua Twp Fire District and TJ McLeer of M&M Electrical LLC.</p> <p>48 KW Generator Installation: - Supply and install Plumbing for the Generator to be installed within 15' of Gas Meter. - Supply and install Auto Transfer Switch (ATS) rated at 400A single phase. - Supply and install Conduit, Fittings, and Wire to existing Panel and Disconnect Switch from the ATS. - Supply and install Conduit, Fittings, and Supports for Emergency Power from Generator to ATS (240/120V) - Supply and install Conduit, Fittings and Wire for Control and 120V Power from the Generator to the ATS.</p> <p>* Conduit to be run on the outside of the Building. M&M Electrical LLC to assist in Start Up of Generator with Generator Representative. Concrete Pad is the responsibility of others and has not been included in this Quote.</p> <p>** Permit fees are the responsibility of Owner and have not been included in this Quote. *** A Tax Exempt Form would be required prior to Bid acceptance, if applicable.</p> <p>Notes: - Any Utility Fees, if applicable, imposed is the responsibility of Owners. - All labor quoted is based on normal working straight time working hours, NJ Prevailing Rate Wages have not been applied. - No Permit fees, Engineering fees, Licensing fees, Bond, or sealed Drawings if applicable are included in this Quote and are the responsibility of others. Sealed Drawings that may be required by Township are not included in this Quote and is the responsibility of others. - Due to the constant fluctuating costs of fuel and materials, our Proposal is valid for a period of sixty (60) days from this date. - Any changes in Scope or resulting in additional work, would be at additional T&M rates, not included in this Quote. - Material costs quoted in this Proposal are based on "standard" shipping times.</p> <p>We appreciate the opportunity to submit our Proposal.</p>	
	Total

* By Signing this Proposal, you have accepted in accordance with these Terms.

Signature 

PROPOSAL

279 Richwood Road
 Mullica Hill, NJ 08062
 License # 12147
 856-582-7440 Telephone

Date	Proposal #
12/29/2016	2760

Name / Address
Mantua Township Fire District Attn: Nick Vacarino 191 Jackson Road Mantua, NJ 08051

Description	Total
<p>~ NJ Sales Tax has been not been included on Labor in this Quote. If this is incorrect, please inform us upon Bid acceptance and tax will be added to this Proposal. The applicable Tax exempt form will be required prior to job start-up.</p> <p>~ M&M Electrical LLC's Payment Terms are Net 20.</p> <p>~ Any delays due to excessive Permit delays, inclement weather or underground obstructions are not included in this Proposal.</p> <p>~ Any work delays due to any/other Contractor's in need of space or area that is beyond our control, causing M&M Electrical LLC lost time needs to be considered. If the amount of time possible lost is unreasonable and necessary tasks are unable to be performed as scheduled, we would need to be compensated. If any of these delays were to arise, M&M Electrical LLC would consult with the Contract Administrator on site for further advisement to discuss a favorable solution to all parties involved.</p> <p>Labor, Material and Equipment</p> <p>NJ Sales Tax</p>	<p>17,490.00</p> <p>0.00</p>

We appreciate the opportunity to submit our Proposal.	Total	\$17,490.00
-------------------------------------------------------	--------------	-------------

* By Signing this Proposal, you have accepted in accordance with these Terms.

Signature

